



City of Leander

**INVITATION FOR BID**

**MAJOR EQUIPMENT**

**QUESTIONS AND ANSWERS**

RFP No. S17-005

Q&A No. 1

Date: November 10th, 2016

Please note the clarification and/or additional information for the solicitation referenced above.

**GENERAL QUESTION**

**1. Q Can equipment be used if a warranty is offered?**

A: No. Per Part I, #6 of the solicitation:

**GOODS:** Respondent warrants and agrees that all items supplied hereunder shall be **NEW** and manufactured and produced in compliance with the laws, regulations, codes, terms, standards, and/or requirements of all Federal, State, and local authorities, and all other authorities having jurisdiction, and that performance of goods shall be in accordance with the above laws, regulations, codes, terms, standards, and/or requirements, and agrees upon request, to furnish the City a certificate of compliance therewith in such forms as the City may require.

**ITEM #4 – Vac Trailer**

**2. Q Is a diesel engine required?**

A: Yes.

**3. Q: Specs indicate skid mount and trailer mount. Is the City seeking both or just the trailer mount?**

A: Skid mount shall be mounted to the trailer.

**4. Q: Specs indicate bulk hose, high temp (4", sold per inch) (95). Please clarify.**

A: 4" bulk hose 20' in length.

**ITEM #6 - Generator 100 KW and Installation**

**5. Q: How far away from the transfer switch rack location will the generator be placed?**

A: Generator is shall be set directly next to the power distribution rack for the building.

**6. Q: Is underground trenching required between the generator and transfer switch? If so how many feet?**

A: Possibly not if contractor can install above ground conduit from generator to power distribution rack still meeting City of Leander Codes and ICC 2015 Electrical Code. Otherwise estimate placement to be within 10 ft.

**7. Q: What type of conduit will be required between the generator and transfer switch?**

A: Successful respondent will be required to meet the City of Leander Codes and ICC 2015 Electrical Code.

8. Q: **Will there be a requirement for a rental generator during the transfer switch electrical installation?**

A: No.

9. Q: **Is privacy fencing required around the generator?**

A: No.

10. Q: **Are there engineered drawings for this project?**

A: No.

11. Q: **Can generator installation be conducted over the weekend?**

A: No. Installation shall be conducted Monday through Friday 8:00 AM to 5:00 PM.

Approved by



---

Joy Simonton, General Services Manager